Global Tender notification to supply and Installation of Scanning Electron Microscope at MNCF, CeNSE, IISc Bangalore

Tender date: 01stAugust 2025

Tender number: CeNSE/MNCF/03/2025-26

CORRIGENDUM- dated 20.08.2025.

Sl. No	Section	As existing in the tender	To be Read as
1	Section 1 - Bid	6. Last Date & Time for	The deadline for
	Schedule	submission of	submission of proposals
		Tender: 22 nd August 2025	is the 28th of August
			2025, 5:00 pm Indian
			Standard Time.
2	Section 4 -	6. Resolution	0.8 nm or better @ 1kV.
	Technical	f) 0.7 nm or better @1 KV	
	Specifications		
3	Section 4 -	r) As an option, EDS with	r) As an option, EDS with
	Technical	following specifications:	following specifications:
	Specifications	s) EDS should be a state of art	s) EDS should be a state
	11. EDS Detector	system designed to work in	of art system designed
	(Optional)	compliance with	to work in compliance
		ISO 15632:2012	with
		t) The EDS detector should be	ISO 15632:2012
		LN2 free type SDD sensor	t) The EDS detector
		based having	should be LN2 free type
		sensor area of at least 100	SDD sensor based
		mm2 or more with the	having
		following published	sensor area of at least
		energy resolution to be	100 mm2 or more with
		guaranteed at site:	Mn-kα resolution
		a. Mn-kα : <127eV at count	<127eV at count rate of
		rate of 100,000cps	100,000cps
		b. F-k α : < 65eV at count rate	or EDS SDD detector
		of 100,000cps	with sensor area of at
		c. C-kα : < 58eV at count rate	least 60mm2 or better
		of 100,000cps	with a Mn resolution of
			<129eV with a high solid
			angle of at least 0.5 str
			or more with output
			count rate up to
			3,000,000 cps or more

Section 4 -	5 Field Emission Gun (FEG)	f. Please specify the
Technical	Replacement: In case the FEG	parameters (such as
Specifications	requires	emission current, probe
24. Warranty	replacement during the	current, image quality,
	warranty or AMC period:	resolution) that can be
		monitored and used as a
		criterion for replacing
		the FEG source
		g. Please specify the
		replacement cost of the
		FEG after the warranty.

Note: The relevant clauses in the tender document referring to the above stands modified accordingly.

Purchase committee.